


# SAFETY RECALL

## Plastic Handle Fire Extinguishers

### Hazard:

The fire extinguisher can become clogged or require excessive force to discharge. In addition, the nozzle can detach with enough force to pose an impact hazard.

**This recall involves two styles of Kidde fire extinguishers: certain plastic handle fire extinguishers and push-button Pindicator fire extinguishers.**



### Description of Products:

The recall involves 23 models of Kidde plastic valve fire extinguishers manufactured between January 1, 1973 and August 15, 2017, including some models that were previously recalled in March 2009 and in February 2015.

### Remedy for Both Fire Extinguisher Types:


Consumers should immediately contact Kidde for instructions regarding return of recalled fire extinguishers and to request a free replacement unit.

**Consumer Contact:** Kidde toll-free at

**1-855-233-2882**

from 8:30 a.m. to 5 p.m. ET Monday through Friday,  
9 a.m. to 3 p.m. ET Saturday and Sunday, or online at [www.kidde.com/fire-safety/en/ca/](http://www.kidde.com/fire-safety/en/ca/) and click on Product Safety Notices for more information.

## Push-Button Pindicator Fire Extinguishers



### Description of Products:

The recall involves six models of Kidde push-button Pindicator fire extinguishers manufactured between August 11, 1995 and September 22, 2017. The no-gauge push-button extinguishers were sold in red and white, and with a red or black nozzle. These models were sold primarily for kitchen and personal watercraft applications.

Scan Code  
with Mobile  
Device for  
More Info



Post through February 2018

In cooperation with Health Canada and  
the U.S Consumer Product Safety Commission.